

1st Sub. S.B. 143

NAIL TECHNICIAN PRACTICE AMENDMENTS

SENATE FLOOR AMENDMENTS

AMENDMENT 1

FEBRUARY 20, 2014 4:51 PM

Senator **Todd Weiler** proposes the following amendments:

1. *Page 2, Lines 46 through 51:*

- 46 (4) In IMC, Table 403.3, Note h is deleted and replaced with the following: "1. For a
47 nail salon where a nail technician files or shapes an acrylic nail, as defined by rule by the Division of
Occupational and Professional Licensing, in accordance with Title 63G, Chapter 3, Utah Administrative
Rulemaking Act, each nail station where a nail
48 technician files or shapes an acrylic nail shall be provided with:
49 a. a source capture system capable of filtering and recirculating air to inside space not
50 less than 50 cfm per station; or
51 b. a source capture system capable of exhausting not less than 50 cfm per station. "
2. Except as provided in paragraph 3, the requirements described in paragraph 1 apply beginning on July 1, 2020.
3. The requirements described in paragraph 1 apply beginning on July 1, 2014 if the nail salon is under or begins new construction or remodeling on or after July 1, 2014. "